



Muscookee County School District
Columbus, Georgia

Jerrell D. Rumph
Senior Buyer

ADDENDUM 2
Bid #26-018 Elevator Maintenance Services

March 25,

Dear Vendors,

On Addendum 1, there was incorrect information provided regarding Question 6.

The original question was:

6. Please confirm the number of yearly visits required for the elevators referenced in the contract?

The previously provided answer was:

One time per year, unless failure or parts need replacing.

Please note the correct answer below:

The elevators are serviced once per month unless a callback is required. This results in 12 service visits per year, and the annual test is included.

Thank you.